



INSPECTION REPORT

Report Issued: Sep 16, 2025

Inspection Result: PARTIAL PASS

Permit Number: SPRMU250880

Issuance Date: Jun 20, 2025

Property Address: 2077 WALTON CREEK RD, UNIT:3;

Applicant: May Riegler Properties, LLC (Gaby & Kevin Riegler)

Contractor: Kocon, LLC PO Box 775735 Steamboat Springs, CO 80477 (970) 819-1983

To construct: Building 1, Unit 3: SPRMU250880

Demolition of existing residential structure. Build new 2-story, with basement & Garage, attached IRC single-family residential townhomes in two distinct buildings. Building #1 consists of 5 Units and Building #2 consists of 3 Units. Each Unit has it's own permit number.

Building 1, Unit 1: SPRMU250307, 2077 Walton Creek Rd

Building 1, Unit 2: SPRMU250879, 2077 Walton Creek Rd

Building 1, Unit 3: SPRMU250880, 2077 Walton Creek Rd

Building 1, Unit 4: SPRMU250881, 2077 Walton Creek Rd

Building 1, Unit 5: SPRMU250882, 2077 Walton Creek Rd

Building 2, Unit 1: SPRMU250883, 2075 Walton Creek Rd

Building 2, Unit 2: SPRMU250884, 2075 Walton Creek Rd

Building 2, Unit 3: SPRMU250885, 2075 Walton Creek Rd

All fees on SPRMU250307

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All #5, retaining and counter fort, double 12' oc mats at 4' and above, below 6"oc. Side walls 12"oc, two top and bottom, low walls two top and bottom. ok to pour

Corrections:



Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us