



# INSPECTION REPORT

**Report Issued:** Sep 18, 2025

**Inspection Result:** **FAILED**

**Permit Number:** SPRSF250159

**Issuance Date:** Jun 24, 2025

**Property Address:** 2400 CHUTES LN;

**Applicant:** FOX CONSTRUCTION

**Contractor:** FOX CONSTRUCTION P.O. BOX 772971 STEAMBOAT SPGS, CO 80477 (970) 879-7529

**To construct:** UNIT B of new DUPLEX- 5,287 SF with 633 SF Attached Garage. 4 Bedroom, 5.5 Bathroom

On this day we have inspected your construction for **Interim Construction Site Management** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments: Address corrections by end of day September 29, 2025.**

## **Corrections:**

- 1 Replace and maintain wire backed silt fence at bottom of slope on the south perimeter. Remove any material that have spilled over the property boundary.
- 2 Clean up and remove concrete washout form access road and provide washout tubs/containers. (see attached photo)

Sincerely,

Scott Slamal  
Stormwater Inspector  
sslamal@steamboatsprings.net

