



# INSPECTION REPORT

**Report Issued:** Sep 18, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRMH241850

**Issuance Date:** Dec 03, 2024

**Property Address:** 1550 AMBLE DR;

**Applicant:** Holly Klein

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** The Amble - Mechanical system, new build

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Snow melt heat tube, tied over 3" foam board, 100 psi

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us