



INSPECTION REPORT

Report Issued: Sep 24, 2025

Inspection Result: PASSED

Permit Number: SPREL251263

Issuance Date: Aug 20, 2025

Property Address: 2075 WALTON CREEK RD;

Applicant: A-PEKS ELECTRIC

Contractor: A-PEKS ELECTRIC 300 Blackberry Ln Steamboat, CO 80487 (970) 734-5050

To construct: Multi Unit new construction. all electrical Unit 1

On this day we have inspected your construction for **Electrical Temp Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Construction service approved

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us