



# INSPECTION REPORT

**Report Issued:** Sep 30, 2025

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRPL251363

**Issuance Date:** Sep 03, 2025

**Property Address:** 2075 WALTON CREEK RD, UNIT:1;

**Applicant:** MOUNTAIN HIGH MECHANICAL

**Contractor:** Kocon, LLC PO Box 775735 Steamboat Springs, CO 80477 (970) 819-1983

**To construct:** Rough plumbing and fixture installation.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** In slab DWV, complete and holding 5 psi

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us