



INSPECTION REPORT

Report Issued: Sep 30, 2025

Inspection Result: PARTIAL PASS

Permit Number: SPRPL251366

Issuance Date: Sep 03, 2025

Property Address: 2075 WALTON CREEK RD, UNIT:3;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: Kocon, LLC PO Box 775735 Steamboat Springs, CO 80477 (970) 819-1983

To construct: Rough plumbing and fixture installation.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: In slab DWV, complete and holding 5 psi

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us