



INSPECTION REPORT

Report Issued: Oct 07, 2025

Inspection Result: PARTIAL PASS

Permit Number: SPRPL241751

Issuance Date: Nov 03, 2024

Property Address: 1760 CENTRAL PARK DR;

Applicant: L&R PLUMBING INC

Contractor: L&R PLUMBING INC 2306 WINFORD AVENUE NASHVILLE, TN 37211 (615) 349-5773

To construct: New Restaurant Plumbing, gas, water, 3,488 Sq Ft
STOP WORK ORDER generated on 04/15/2025 by username 'Todd Carr'.
STOP WORK ORDER removed on 05/06/2025 by username 'Barbara Fox'.

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Temp Heat Inspection: Four gas lines run to temp heaters on all floors passed test of 5psi. Temp green tag issued. ! ball valve will shut down entire temp heat system and emergency shut off clearly marked with orange sign.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us