



INSPECTION REPORT

Report Issued: Oct 08, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRSF250158

Issuance Date: Jun 25, 2025

Property Address: 2402 CHUTES LN;

Applicant: FOX CONSTRUCTION

Contractor: FOX CONSTRUCTION P.O. BOX 772971 STEAMBOAT SPGS, CO 80477 (970) 879-7529

To construct: UNIT A of New DUPLEX: 5,698 SF with 632 SF Attached Garage. 5 Bedroom, 5.5 Bathroom

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Foundation walls on grids E and F between 1-12, walls along 11-12 between F and J and walls between 1 and 5.5 and L to front corner are all formed to approved plans. All rebar in these areas are correctly sized and spaced. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us