



INSPECTION REPORT

Report Issued: Oct 02, 2025

Inspection Result: PASSED

Permit Number: SPRSF250159

Issuance Date: Jun 24, 2025

Property Address: 2400 CHUTES LN;

Applicant: FOX CONSTRUCTION

Contractor: FOX CONSTRUCTION P.O. BOX 772971 STEAMBOAT SPGS, CO 80477 (970) 879-7529

To construct: UNIT B of new DUPLEX- 5,287 SF with 633 SF Attached Garage. 4 Bedroom, 5.5 Bathroom

On this day we have inspected your construction for **Interim Construction Site Management** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Follow up from 9/17 failed inspection

Corrections:

- 1 Replace and maintain wire backed silt fence at bottom of slope on the south perimeter. Remove any material that has spilled over the property boundary.
- 2 Clean up and remove concrete washout and provide washout tubs/containers.

Sincerely,

Scott Slamal
Stormwater Inspector
sslamal@steamboatsprings.net