



# INSPECTION REPORT

**Report Issued:** Oct 13, 2025

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRPL251590

**Issuance Date:** Oct 07, 2025

**Property Address:** 1750 CENTRAL PARK DR;

**Applicant:** MKE Mechanical LLC

**Contractor:** NGC Group, Inc. 1935 O Street, Suite 1 Lincoln, NE 68510

**To construct:** Installing underground exterior gas lines

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** 1-6", 1-4", 1-3", 1-2" and 1-1 1/4" gas lines all installed at proper depth with trace wire from meter location to final exterior locations. All 5 gas lines passed test of 30psi. Approved, Ok to backfill

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us