



INSPECTION REPORT

Report Issued: Oct 15, 2025

Inspection Result: PASSED

Permit Number: SPRRN251497

Issuance Date: Sep 30, 2025

Property Address:

Applicant: Gavin Malia

Contractor: STEAMBOAT SKI & RESORT CORP 2305 MT. WERNER CIR STEAMBOAT SPGS,
CO 80487 (678) 863-8219

To construct: Project to replace the lift gates at the Wildblue Gondola and Steamboat
Gondola with a new rack system for the new gates to hang on. It will consist
of sonotube pier foundations supporting a steel structure that the gates will
hang from.

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Remaining pier form to approve plans, rebar installed is sized and spaced correctly. Approved.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us