



INSPECTION REPORT

Report Issued: Oct 17, 2025

Inspection Result: PARTIAL PASS

Permit Number: SPRPL241751

Issuance Date: Nov 03, 2024

Property Address: 1760 CENTRAL PARK DR;

Applicant: L&R PLUMBING INC

Contractor: L&R PLUMBING INC 2306 WINFORD AVENUE NASHVILLE, TN 37211 (615) 349-5773

To construct: New Restaurant Plumbing, gas, water, 3,488 Sq Ft
STOP WORK ORDER generated on 04/15/2025 by username 'Todd Carr'.
STOP WORK ORDER removed on 05/06/2025 by username 'Barbara Fox'.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Remain 4 shower bases installed and all held water for test duration in units 104, 154, 204 and 254. Waterlines in these units also passed test of 100psi. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us