



INSPECTION REPORT

Report Issued: Oct 22, 2025

Inspection Result: PASSED

Permit Number: SPRMH250340

Issuance Date: Apr 01, 2025

Property Address: 2700 VILLAGE DR;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: GARCIA CONSTRUCTION LIMITED 1153 OAK STREET STEAMBOAT SPRINGS,
CO 80477 (970) 757-3250

To construct: Installing gas line, ERV, 4 unit heaters and 2 de-stratification per mechanical plans

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Unit heater installed and properly vented. Heaters hooked to gas line and ready to fire. Green tag issued.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us