



INSPECTION REPORT

Report Issued: Oct 30, 2025

Inspection Result: PASSED

Permit Number: SPRMH251732

Issuance Date: Oct 29, 2025

Property Address: 1920 BRIDGE LN, UNIT:11;

Applicant: Perfect Routt

Contractor: Perfect Routt 23800 CR 16, 301 Oak Creek, CO 80467

To construct: Strapping on un inspected fart fan requested by Todd carr installed

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Dryer and bath fan lines are now strapped per previous conversation with inspector, all other mechanical work is up to code as installed. Final approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us