



INSPECTION REPORT

Report Issued: Nov 03, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL241239

Issuance Date: Aug 21, 2024

Property Address: 1760 CENTRAL PARK DR;

Applicant: L&R PLUMBING INC

Contractor: L&R PLUMBING INC 2306 WINFORD AVENUE NASHVILLE, TN 37211 (615) 349-5773

To construct: New Plumbing Installation for new hotel
STOP WORK ORDER generated on 04/15/2025 by username 'Todd Carr'.
STOP WORK ORDER removed on 05/06/2025 by username 'Barbara Fox'.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Interior gas lines approved, approved line from mechanical room on main floor to adjacent room which is laundry room, single line ran black flex line holding 16 psi from manifold to dryer location. Then approved a gas line in main dining hall ran in pre installed conduit under slab to fireplace unit on exterior wall, holding 16 psi, then approve line from pool mechanical room and another fireplace in restaurant area, holding 16 psi ran above ceiling area.

Corrections:

Sincerely,

Todd Carr
Building Official



tcarr@co.routt.co.us