



INSPECTION REPORT

Report Issued: Nov 06, 2025

Inspection Result: PARTIAL PASS

Permit Number: SPRPL251590

Issuance Date: Oct 07, 2025

Property Address: 1750 CENTRAL PARK DR;

Applicant: MKE Mechanical LLC

Contractor: NGC Group, Inc. 1935 O Street, Suite 1 Lincoln, NE 68510

To construct: Installing underground exterior gas lines

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 2" gas lines into the building, holding 40 psi

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us