



# INSPECTION REPORT

**Report Issued:** Nov 12, 2025

**Inspection Result:** PASSED

**Permit Number:** SPRPL251348

**Issuance Date:** Sep 02, 2025

**Property Address:** 127 11TH ST;

**Applicant:** TBH PLUMBING & HEATING

**Contractor:** TBH PLUMBING & HEATING 515 Routt St. STEAMBOAT SPGS,, CO 80487 (970) 846-4702

**To construct:** Installation of new water meter system. Tie into new water main and existing water line in building.

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Plumbing final approved, all work completed with new strainer, backflow, meter and valves installed at entry to building

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us