



INSPECTION REPORT

Report Issued: Nov 20, 2025

Inspection Result: PASSED

Permit Number: SPRMH251670

Issuance Date: Oct 20, 2025

Property Address: 1855 SKI TIME SQUARE DR;

Applicant: LARAMIE MECHANICAL & HEATING

Contractor: LARAMIE MECHANICAL & HEATING 1404 skyline road LARAMIE, WY 82070
(307) 745-7255

To construct: Pizza over exhaust, Replace RTU

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Venting for pizza, oven, double wall vent, supported and protected through the roof thimble, with powered vent on roof. No clearance issues.

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us