



INSPECTION REPORT

Report Issued: Nov 24, 2025

Inspection Result: PASSED

Permit Number: SPRRN251479

Issuance Date: Oct 06, 2025

Property Address: 2700 VILLAGE DR;

Applicant: ELK COUNTRY RENOVATIONS LLC

Contractor: ELK COUNTRY RENOVATIONS LLC 625 COUNTY RD CRAIG, CO 81625 (970) 326-7024

To construct: Enlarge existing bedroom closet to accommodate washer/dryer'
Build new owner closet and bedroom closet in bedroom.
Replace fire place.
new tile showers in bathrooms.

On this day we have inspected your construction for **Shower Pan** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 2 shower pans with schluter pans approved holding water for 15 minutes

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us