



INSPECTION REPORT

Report Issued: Nov 25, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH241850

Issuance Date: Dec 03, 2024

Property Address: 1550 AMBLE DR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: The Amble - Mechanical system, new build

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Pool area snow melt tubing, holding 100 psi and bulb gauges, tied over foam board

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us