



INSPECTION REPORT

Report Issued: Dec 02, 2025

Inspection Result: PARTIAL PASS

Permit Number: SPREL251881

Issuance Date: Nov 30, 2025

Property Address: 1920 BRIDGE LN, UNIT:11;

Applicant: Red Hawk Electric

Contractor: Red Hawk Electric 23500 Sagebrush Circle OAK CREEK, CO 80467--8602

To construct: Checking existing wiring to make sure it is safe and up to code.

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Build out will require arc fault and GFI protection per current code cycle

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us