



# INSPECTION REPORT

**Report Issued:** Dec 04, 2025

**Inspection Result:** PASSED

**Permit Number:** SPRPL240132

**Issuance Date:** Feb 10, 2024

**Property Address:** 2940 VILLAGE DR; 2944 VILLAGE DR; 2948 VILLAGE DR; 2956 VILLAGE DR; 2936 VILLAGE DR;

**Applicant:** CROSS MOUNTAIN PLMB & HEAT

**Contractor:** CROSS MOUNTAIN PLMB & HEAT P.O. BOX 771905 STEAMBOAT SPGS,, CO 80477 (970) 819-4276

**To construct:** New construction DWV, water piping, gas piping, and fixture set.

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** All fixtures and drains are complete in operational

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us