



# INSPECTION REPORT

**Report Issued:** Dec 15, 2025

**Inspection Result:** PASSED

**Permit Number:** SPREL251873

**Issuance Date:** Nov 26, 2025

**Property Address:** 1122 LINCOLN AVE;

**Applicant:** Advanced Electrical Contracting Inc

**Contractor:** Advanced Electrical Contracting Inc 1663 Commercial Ave Sheridan, WY  
82801

**To construct:** Upgraded existing meter to new 400 amp disconnect with CT cabinet and CT meter.

On this day we have inspected your construction for **Electrical Perm Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Parent service approved for 400 amp CT service on back of Western Lodge

**Corrections:**

Sincerely,

Tom Cook  
Electrical Plan Reviewer/Inspector  
tcook@co.routt.co.us