



INSPECTION REPORT

Report Issued: Dec 17, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPREL251821

Issuance Date: Nov 21, 2025

Property Address: 2305 MT WERNER CIR;

Applicant: Stephen Patterson

Contractor: TOLIN MECHANICAL SYSTEMS CO. 12005 E. 45TH AVE. DENVER, CO 80239-3111 (303) 859-0261

To construct: Add 2 new electrical services to existing panel to feed new exhaust fan and fan coil unit (permit SPRMH251806).

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Final electrical conditionally approved for use. one correction remaining, disconnect switch to be installed at remote fan Within 10 working days of today's date.

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us