



INSPECTION REPORT

Report Issued: Dec 22, 2025

Inspection Result: PASSED

Permit Number: SPRPL251951

Issuance Date: Dec 18, 2025

Property Address: 1900 BRIDGE LN, UNIT:6A;

Applicant: Isidro Quezada

Contractor: IQ PLUMBING & HEATING 895 RANNEY ST CRAIG, CO 81625 (970) 629-5125

To construct: Adding a vent to toilet and install vent to the upper plumbing system from the lower level. New drain line to kitchen and to laundry in 1st floor.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: New PVC lines for washer and sink in downstairs are installed correctly, lines tested live with no leaks detected. New water lines are installed correctly, tested live with no leaks detected. Rough plumbing approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us