



INSPECTION REPORT

Report Issued: Dec 31, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPREL251965

Issuance Date: Dec 30, 2025

Property Address: 927 OAK ST;

Applicant: Sturgeon Electric Company, Inc.

Contractor: Sturgeon Electric Company, Inc. 12121 Grant St, Suite 610 Thornton, CO 80241

To construct: Placing a new meter for Comcast power supply in the alley between the fire station and Centennial hall.

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial approval for service. main service disconnect missing main Bond jumper recall when corrected

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us