



INSPECTION REPORT

Report Issued: Jan 16, 2026

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH240034

Issuance Date: Jan 10, 2024

Property Address: 2964 VILLAGE DR;

Applicant: CROSS MOUNTAIN PLMB & HEAT

Contractor: CROSS MOUNTAIN PLMB & HEAT P.O. BOX 771905 STEAMBOAT SPGS,, CO 80477 (970) 819-4276

To construct: Radiant heat system, snow melt system.
South Bldg 2964 & 2968 Village Dr

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Snow melt tubing is installed and fastened correctly over our 10 phone board. Pressure test good at 100 psi for 15 minutes. Approved to pour.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us