



INSPECTION REPORT

Report Issued: Feb 25, 2026

Inspection Result: PASSED

Permit Number: SPRMH251500

Issuance Date: Sep 23, 2025

Property Address: 1750 CENTRAL PARK DR;

Applicant: Fox Mechanical, LLC

Contractor: Fox Mechanical, LLC 4975 N Van Gordon St Wheatridge, CO 80033

To construct: Ptacs, Fan coils, and Exhaust fans for a Hotel.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Grease duct has now been connected and supported from shaft to hood. Smoke test good with no leaks detected. Approved to close mechanical shaft.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us