



INSPECTION REPORT

Report Issued: Mar 05, 2026

Inspection Result: **PARTIAL PASS**

Permit Number: SPREL241278

Issuance Date: Aug 27, 2024

Property Address: 1550 AMBLE DR;

Applicant: Mike Barboza

Contractor: Lakewood Electric Company 3533 Timber Mill Pkwy, Suite A Castle Rock, CO 80109

To construct: New 5-Story Condo Building with 42 Units, with underground parking garage, amenities include a fitness room and lounge on main floor.

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Final approved for first second and third floor entirety. Partial final approved for 4th floor units with corrections for hot tubs seat correction list. 4th Floor Electric AV and mechanical rooms approved

Corrections:

- 1 All conductive surfaces within 30 in of water edge not lower than 28 in below top of tub require potential bonding. Luminaries directly above hot tub in violation

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us