



# INSPECTION REPORT

**Report Issued:** Mar 12, 2026

**Inspection Result:** PASSED

**Permit Number:** SPRPL241239

**Issuance Date:** Aug 21, 2024

**Property Address:** 1760 CENTRAL PARK DR;

**Applicant:** L&R PLUMBING INC

**Contractor:** L&R PLUMBING INC 2306 WINFORD AVENUE NASHVILLE, TN 37211 (615)  
349-5773

**To construct:** New Plumbing Installation for new hotel  
STOP WORK ORDER generated on 04/15/2025 by username 'Todd Carr'.  
STOP WORK ORDER removed on 05/06/2025 by username 'Barbara Fox'.

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Entire gas line system retested to 15psi. All appliances hooked to gas line and ready to fire except 2 fireplaces and restaurant equipment. Approved, green tag issued

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us