



INSPECTION REPORT

Report Issued: Mar 12, 2026

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH250212

Issuance Date: Mar 05, 2025

Property Address: 2940 VILLAGE DR; 2944 VILLAGE DR; 2948 VILLAGE DR; 2956 VILLAGE DR; 2936 VILLAGE DR;

Applicant: Steamboat Heat LLC

Contractor: Steamboat Heat LLC 32555 County Road 38 Steamboat Springs , CO 80487
(970) 581-6978

To construct: HVAC and all mechanical ventilation.
2936, 2940, 2944, 2948, 2956 Village DR

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: All units have bathroom fans operational and range exhaust operational. All grilles installed. Will see ERV's and A/C when completed. Good for tco.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us