



# INSPECTION REPORT

**Report Issued:** Mar 12, 2026

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRMH241850

**Issuance Date:** Dec 03, 2024

**Property Address:** 1550 AMBLE DR;

**Applicant:** Holly Klein

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** The Amble - Mechanical system, new build

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: Level 4 ductwork in electrical rooms completed to approved plans. All ducts are properly supported and sealed. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us