



INSPECTION REPORT

Report Issued: Mar 18, 2026

Inspection Result: **PARTIAL PASS**

Permit Number: SPREL241278

Issuance Date: Aug 27, 2024

Property Address: 1550 AMBLE DR;

Applicant: Mike Barboza

Contractor: Lakewood Electric Company 3533 Timber Mill Pkwy, Suite A Castle Rock, CO 80109

To construct: New 5-Story Condo Building with 42 Units, with underground parking garage, amenities include a fitness room and lounge on main floor.

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Final electrical approved for TCO. Only remaining items are EV Chargers and equipotential plane for 4th floor hot tubs. Hot tubs are okay to operate but not to be occupied until bonding complete. Recall when EV Chargers installed and equipped potential plane installed

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us