



INSPECTION REPORT

Report Issued: Mar 25, 2026

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240967

Issuance Date: Jul 18, 2024

Property Address: 1550 AMBLE DR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: all units on 3rd and 4th floors have fixtures installed, sealed and operational. Approved. Will inspect common areas and mechanical rooms at later inspection. Partial approved

Corrections:

- 1 Building Department Corrections to be Completed
Reinspect 111 toilets, 105 toilets, kitchen sink, 102 toilet, 109 and 106 guest tub

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us