



INSPECTION REPORT

Report Issued: Mar 30, 2026

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL260308

Issuance Date: Mar 29, 2026

Property Address: 1920 BRIDGE LN, UNIT:8A;

Applicant: J & I Plumbing and Heating Services LLC

Contractor: J & I Plumbing and Heating Services LLC 1664 Yampa Ave Craig, CO 81325

To construct: rough in for toilet/toilet/sink
and washer.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV line for macerating toilet and lavatory are installed correctly. Tested under water flow with no leaks. Water lines for shower, lav and toilet are installed, supported and protected correctly. Lines are live with no leaks. DWV line for shower will need a individual vent installed and tied to toilet vent, can see later. Partial approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us