



INSPECTION REPORT

Report Issued: Mar 30, 2026

Inspection Result: NOT READY

Permit Number: SPRPL260308

Issuance Date: Mar 29, 2026

Property Address: 1920 BRIDGE LN, UNIT:8A;

Applicant: J & I Plumbing and Heating Services LLC

Contractor: J & I Plumbing and Heating Services LLC 1664 Yampa Ave Craig, CO 81325

To construct: rough in for toilet/toilet/sink
and washer.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments:

Corrections:

Sincerely,

Tammy Green
Permit Tech
tkgreen@co.routt.co.us