



INSPECTION REPORT

Report Issued: Aug 23, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPREL210062

Issuance Date: Aug 20, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: CENTRAL ELECTRIC, LLC 2659 Jacob Cir #4 STEAMBOAT SPGS,, CO 80487
(970) 846-8379

To construct: Underground electrical

On this day we have inspected your construction for **Electrical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Underground around gondola structure approved between operator shack and utility room

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us