



INSPECTION REPORT

Report Issued: Sep 03, 2021

Inspection Result: PARTIAL PASS

Permit Number: P-21-282

Issuance Date: Jun 25, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: Work Description: Underground Waste and Vent.

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Escalator pump drain to sand / oil interceptor with a 6 psi test for 15 is good Future grease waste line under slab with 5 psi test for 15 minutes is good

Corrections:

Sincerely,

Don Marchbanks
Inspector
dmarchbanks@co.routt.co.us