



INSPECTION REPORT

Report Issued: S	Sep 20, 2021	Inspection Result:	PARTIAL PASS
------------------	--------------	--------------------	--------------

Permit Number: SPRMH210052 Issuance Date: Aug 19, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: Saunders Construction, LLC 86 Inverness Place North Englewood, CO 80112

(408) 656-9910CENTRAL ELECTRIC, LLC 2659 Jacob Cir #4 STEAMBOAT SPGS,, CO 80487 (970) 846-8379MTech Mechanical Technologies Group 12300 Pecos

Street Westminster, Co 80234 (719) 782-4000

To construct: Install single boiler and install hydronic

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: hydronic steel lines 4 total from parking garage underground to just inside promenade foundation wall approved, held 90 psi each. May insulated pipe then back fill.

Corrections:

Sincerely,

Todd Carr Building Official tcarr@co.routt.co.us