



INSPECTION REPORT

Report Issued: Sep 24, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRPL210327

Issuance Date: Sep 23, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: GSQ/KVC Plumbing reno

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Area A - water pipe for restrooms and break room with 3 100 psi test gauges is good Area C - restrooms water pipe with a 100 psi test is good All pipe and pipe support is good

Corrections:

Sincerely,

Don Marchbanks
Inspector
dmarchbanks@co.routt.co.us