



# INSPECTION REPORT

**Report Issued:** Sep 27, 2021

**Inspection Result:** PASSED

**Permit Number:** SPRRF210212

**Issuance Date:** Sep 22, 2021

**Property Address:** 2320 SKI TRAIL LN;

**Contractor:** REVELATION ROOFING OF THE ROCKIES P.O. BOX 1687 HAYDEN, CO 81639  
(970) 846-4385

**To construct:** shingles: tear off existing shingles  
dry in new ice and water 100%  
new flashing and new shingles  
48 squares  
EPDM: prep existing EPDM roofing  
install new recovery board  
install fully adhered EPDM 60 mil.  
45 squares

On this day we have inspected your construction for **Roofing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** New EPDM over Poly-Iso completed on upper flat roof. New Grace Ice and WaterShield installed on all other pitches.

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us