



INSPECTION REPORT

Report Issued: Sep 27, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRMH210323

Issuance Date: Sep 23, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co
80234 (719) 782-4000

To construct: KVC/GSQ TI Reno

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Round ducts down stream from VAS's have been installed, supported and sealed correctly to approved plans. Approved to insulate.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us