



# INSPECTION REPORT

**Report Issued:** Sep 27, 2021

**Inspection Result:**

**PARTIAL PASS**

**Permit Number:** B-21-632

**Issuance Date:** Jul 15, 2021

**Property Address:** 2305 MT WERNER CIR;

**Contractor:** Saunders Construction, LLC 86 Inverness Place North Englewood, CO 80112  
(408) 656-9910

**To construct:** Work Description: A. The Work of Project is defined by the Contract Documents The work is to include the interior renovation of the Existing Gondola Square Buildings - A, C, and F an existing building to create business occupancy workspace. The work will include new partitions, ceilings, finishes, mechanical, electrical, and plumbing, Minor exterior work for louver intakes and exhausts supporting the interior renovations is also included.

GSQ Total Project cost: \$1,792,825.00

BedroomsNoEx: 0

BedroomsNoProp: 0

HeightofConstructionEx: 0.00

HeightofConstructionProp: 0.00

LivingAreaEx: 0.00

LivingAreaProp: 0.00

SignLength: 0.00

SignWidth: 0.00

StoriesNoEx: 0

StoriesNoProp: 0

TotalAreaEx: 0.00

TotalAreaProp: 0.00

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.



**Comments:** A03 bathrooms, C02 bathrooms have been framed to approved plans. Approved to drywall.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us