



INSPECTION REPORT

Report Issued: Sep 28, 2021

Inspection Result: PASSED

Permit Number: SPRRF210212

Issuance Date: Sep 22, 2021

Property Address: 2320 SKI TRAIL LN;

Contractor: REVELATION ROOFING OF THE ROCKIES P.O. BOX 1687 HAYDEN, CO 81639
(970) 846-4385

To construct: shingles: tear off existing shingles
dry in new ice and water 100%
new flashing and new shingles
48 squares
EPDM: prep existing EPDM roofing
install new recovery board
install fully adhered EPDM 60 mil.
45 squares

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All work completed. EPDM completed and shingles completed with new drip edge

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us