



# INSPECTION REPORT

**Report Issued:** Oct 05, 2021

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRMH210323

**Issuance Date:** Sep 23, 2021

**Property Address:** 2305 MT WERNER CIR;

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co  
80234 (719) 782-4000

**To construct:** KVC/GSQ TI Reno

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** KVC Hydronic pipe throughout on 100 psi test on 4 gauges All tests are good Pipe and pipe support is good

**Corrections:**

Sincerely,

Don Marchbanks  
Inspector  
dmarchbanks@co.routt.co.us