



INSPECTION REPORT

Report Issued:	Oct 07, 2021	Inspection Result:	PARTIAL PASS
Issuance Date:	B-21-625 Jul 22, 2021 2305 MT WERNER CIR;		
Contractor:	Saunders Construction, LL (408) 656-9910	C 86 Inverness Place North	Englewood, CO 80112
To construct:	Work Description: The Wo and consists of new constr Village. The work for the Goldwalk the Goldwalk. BedroomsNoEx: 0 BedroomsNoProp: 0 HeightofConstructionEx: 0 HeightofConstructionProp LivingAreaEx: 0.00 LivingAreaProp: 0.00 SignLength: 0.00 SignWidth: 0.00 StoriesNoEx: 0 StoriesNoProp: 1 TotalAreaEx: 0.00 TotalAreaProp: 12883.00	uction and renovation of t project includes a new en	he Steamboat Base
	10101 1001 1001 12000.00		

On this day we have inspected your construction for **Structural Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Structural Reinforcement for Grand Stair Slab double layer rebar mats are per approved plans OK to pour





Corrections:

Sincerely,

Don Marchbanks Inspector dmarchbanks@co.routt.co.us