



INSPECTION REPORT

Report Issued: Oct 07, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRPL210192

Issuance Date: Sep 02, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: Boiler Plant & Goldwalk plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 6" gas pipe from meter location to boiler room serving all boilers Pipe pipe support and pressure test is good Schedule Approval for service when ready for gas

Corrections:

Sincerely,

Don Marchbanks
Inspector
dmarchbanks@co.routt.co.us