



# INSPECTION REPORT

**Report Issued:** Oct 07, 2021

**Inspection Result:** PASSED

**Permit Number:** SPRRF210280

**Issuance Date:** Oct 04, 2021

**Property Address:** 2350 SKI TRAIL LN;

**Contractor:** TIN MAN ROOFING & Construction P.O. BOX 770478 STEAMBOAT SPGS, CO 80477 (970) 846-0020

**To construct:** Roof is a 2 part roof. Flat section is EPDM rubber membrane and center pitched roof is composite/asphalt shingles. We will keep the same blend or proportions. We will tear off and replace with new/same materials

On this day we have inspected your construction for **Roofing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Grace Ice and WaterShield installed on pitched area of roof on office building. All laps are good. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us