



INSPECTION REPORT

Report Issued: Oct 13, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRPL210192

Issuance Date: Sep 02, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: Boiler Plant & Goldwalk plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: New gas pipe for outdoor fireplace along new foundation wall From firepit location to northwest corner foundation wall 10 psi test for 15 minutes is good Trench depth and trace wire are good OK to backfill

Corrections:

Sincerely,

Don Marchbanks
Inspector
dmarchbanks@co.routt.co.us