



INSPECTION REPORT

Report Issued: Oct 18, 2021

Inspection Result: PARTIAL PASS

Permit Number: SPRMH210323

Issuance Date: Sep 23, 2021

Property Address: 2305 MT WERNER CIR;

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: KVC/GSQ TI Reno

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Area 1,2,and 3 KVC. All above ceiling ducts run to approximate locations on Approved Plans. All ducts are properly supported and sealed with duct stiffeners as needed. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us